

**SAFETY  
SEALING  
SYSTEMS**

**BEELE**  
WE CARE

**FISSIC® FIRE PROOF COATING  
GAS TIGHT SURFACE,  
NO WATER ABSORPTION  
SALT WATER RESISTANT**

**FISSIC**



**TECHNOLOGY DEVELOPED BY BEELE ENGINEERING BV  
COMPOUNDING AND PRODUCTION IN THE ULTRA-MODERN  
MANUFACTURING FACILITIES IN AALTEN/THE NETHERLANDS  
UNDER A STRINGENT ISO 9001:2015 QUALITY SYSTEM  
MORE THAN 40 YEARS R&D ON QUALITY, DURABILITY & FUNCTIONALITY**

Beele campus 45.000 m<sup>2</sup>  
building phase 1 starts early 2017



**Copyright**

: BEELE Engineering BV/CSD International BV, Aalten, the Netherlands.  
Proprietary rights on all drawings and technical data released in this brochure. © 1997-2017

**Edition**

: March 2017

**Note**

: No part of this publication may be reproduced without explicit written approval of BEELE Engineering BV.

**Research & Development**

: BEELE Engineering BV, Aalten, the Netherlands.

**Note**

: The manufacturer reserves the right to make dimensional and design modifications without prior notification.

®

: ACTIFOAM, AQUASTOP, BEEBLOCK, BEEBOND, BEELE, BEELE WE CARE, BEESEAL, BEMITITE, BLOCKSTACK, CONDUCTION, CONTROFIL, CRUSHER, CRUSHNOF, CSD, CSD THE SIMPLE SEAL SYSTEM, DRIFIL, DYNATITE, FIRAQUA, FIREQUAKE, FIRSTO, FISSIC, FIWA, GLANDMOD, LEAXEAL, MULTI-ALL-MIX, NOFIRNO, profiles NOFIRNO gaskets, RAPID TRANSIT SYSTEM, REVITITE, RESITITE, RIACNOF, RISE, RISWAT, SEALING VALLEY, S, SLIPSIL, flanges SLIPSIL plugs, ULEPSI, XATTAX and YFESTOS are registered trade marks of BEELE Engineering.

**brochure code**

: installation NOFIRNO blind



a product developed and manufactured  
by BEELE Engineering bv/Netherlands  
website: [www.fissiccoating.com](http://www.fissiccoating.com)

# FISSIC®

**FISSIC®** is a fire retardant coating on the basis of an APEO-free water-based polymer emulsion without the addition of VOC containing solvents.

**FISSIC®** has been tested successfully on flame spread characteristics and toxicity and is classed as "not capable of producing excessive quantity of smoke or toxic product".  
MED certificate 39278/A0 EC issued by Bureau Veritas.

**FISSIC®** is fire proof and salt water resistance (even after fire). KIWA Netherlands report 20150421HN01.

**FISSIC®** is gas tight 30 mBar.

**FISSIC®** is water impermeable. KIWA Netherlands report 20160203TW01

**FISSIC®** resistance to diesel & petrol. KIWA Netherlands report 20160224TW01

**FISSIC®** prevents "CUI - corrosion underneath insulation"

**FISSIC®** successfully SBI tested according to EN 13823:2010 for B-1s-d0 class rating

**FISSIC®** successfully tested according to ISO 1716 for A2-1s-d0 noncombustible

**FISSIC®** adhesion 3.84 MPa according to ISO 4624:08-2003. KIWA report P 10498a

## FISSIC® COATING OFFICIALLY TESTED AND CERTIFIED

Page 1 / 2



Marine & Offshore  
Division

Certificate number: 39278/A0 EC  
File number: ACI 1330/088/001  
Annex A1 Item number: A.1/3.18b  
USCG Module B number: 164.112 / EC0062

*This certificate is not valid when presented without the full  
attached schedule composed of 7 sections*  
www.veristar.com

Notified Body 0062 - MARINE EQUIPMENT DIRECTIVE 96/98/EC

### EC TYPE EXAMINATION CERTIFICATE

as per Module B of European Union Council Directive 96/98/EC on marine equipment  
as amended by Commission Directive 2012/32/EU

*This certificate is issued to*

**BEELE ENGINEERING**  
Aalten - NETHERLANDS

*for the type of product*

### SURFACE MATERIALS AND FLOOR COVERINGS WITH LOW FLAME-SPREAD CHARACTERISTICS: PAINT SYSTEMS

Fissic fire resistant, water resistant coating

**Requirements:**


SOLAS 74 convention as amended, Regulations II-2/3, II-2/5, II-2/6, II-2/9, X/3  
IMO Resolution MSC.97(73) - (2000 HSC Code) 7  
IMO MSC.307(88) (2010 FTP Code) Annex 1 Part 2 and Part 5  
IMO MSC/Circ.1120  
ISO 1716 (2010)

*This certificate is issued under the French Maritime Authority to attest that BUREAU VERITAS did undertake the relevant type-examination  
procedures for the product identified above which was found to comply with the relevant requirements of the Council Directive 96/98/EC of 20  
December 1996 as amended.*

**This certificate will expire on: 26 Sep 2019**

For BUREAU VERITAS Notified Body 0062,  
At BV GRONINGEN, on 26 Sep 2014,  
John Mondt



This certificate does not allow to issue the Declaration of Conformity and to affix the mark of conformity (wheelmark ) to the products corresponding to this type. To this end, the production-control phase module (D, E or F) of Annex B of the Directive is to be complied with and controlled by a written inspection agreement with a notified body.

This certificate remains valid until the date stated above, unless cancelled or revoked, provided the conditions indicated in the subsequent page(s) are complied with and the product remains satisfactory in service. This certificate will not be valid if the applicant makes any changes or modifications to the approved product, which have not been notified to, and agreed in writing with BUREAU VERITAS. Should the specified regulations or standards be amended during the validity of this certificate, the product(s) is/are to be re-approved prior to it/they being placed on board vessels to which the amended regulations or standards apply. BUREAU VERITAS is designated by the French Maritime Authority as a "notified body" under the terms of the French Regulations Division 140 Chapter 140-2. This certificate is issued within the scope of the General Conditions of BUREAU VERITAS Marine & Offshore Division available on the internet site www.veristar.com. Any Person not a party to the contract pursuant to which this document is delivered may not assert a claim against BUREAU VERITAS for any liability arising out of errors or omissions which may be contained in said document, or for errors of judgement, fault or negligence committed by personnel of the Society or of its Agents in establishment or issuance of this document, and in connection with any activities for which it may provide.

The electronic version is available at: <http://www.veristarp.com/veristarnb/jsp/viewPublicPdfType.jsp?id=dm7dovez6>

BV Mod. Ad.E 536 May 2009

This certificate consists of 2 page(s)

SALT FOG SPRAY TESTING EQUIPMENT IN THE  
R&D LABORATORIES OF BEELE ENGINEERING.




STEEL PIPE PARTLY COATED WITH FISSIC® AND  
WITH FISSIC® ENCAPSULATED MINERAL WOOL



THE EQUIPMENT IS ABLE TO PERFORM SALT FOG TESTS ACCORDING TO SEVERAL STANDARDS. PROGRAMMING FOR THE TEST EN-ISO 9227:2012.



THE TEST SPECIMEN EXPOSED FOR 24 HOURS  
AT A TEMPERATURE OF 35 °C TO A 5% SODIUM  
CHLORIDE SOLUTION WITH A pH OF 6.8.





THE NON-TREATED PART OF THE STEEL PIPE  
CORRODED, THE FISSIC® COATING NOT AFFECTED



THE WITH FISSIC® COATING ENCAPSULATED  
MINERAL WOOL AFTER EXPOSURE TO THE SALT  
FOG TEST



THE EN 10216-1/10210 - DIN (2448) St. 52-3N  
STEEL PIPE AFTER EXPOSURE



**SALT FOG SPRAY TEST EXPOSURE TO A STEEL PIPE COATED WITH FISSIC® AFTER A 60 MINUTES A-60 FIRE TEST. OFFICIAL TEST REPORT.**



20150421HN/01  
21 April 2015

**FISSIC coating:**

**Resistance to neutral salt spray test (NSS)  
after a A60 fire test**



**GAS TIGHTNESS TEST ON A FISSIC® LAYER APPLIED ON  
MINERAL WOOL.  
OFFICIAL REPORT ISSUED BY KIWA NEDERLAND.**



TEST CARRIED OUT AT 38 mBAR



**A FISSIC® LAYER APPLIED ON MINERAL WOOL  
EXPOSED FOR ALMOST 2 YEARS TO WATER.  
KIWA NEDERLAND REPORT 20160203TWOI.**

**NO POLLUTION OF THE  
WATER, NO LOSS OF  
WATER.  
AFTER TWO YEARS  
EXPOSURE - NO DEGRADATION  
OF THE FISSIC® LAYER, NO  
MOISTURE PENETRATED  
INTO THE MINERAL WOOL.**



FISSIC® COATING SUBMERGED DIESEL (BOTTOM)  
PETROL (MIDDLE) AND WATER FOR ONE WEEK  
TO DETERMINE DEGRADATION, WEIGHT LOSS  
AND RESISTANCE.  
KIWA NEDERLAND REPORT 20160224TWOI.






EACH OF THE THREE EXPOSED  
SAMPLES IN THE LIQUIDS  
MEASURED ON PHYSICAL  
CHANGES TO NEW MATERIAL



STEEL PIPE COATED WITH A LAYER OF  
FISSIC® COATING < 1 mm THICK EXPOSED  
TO A STANDARD CELLULOSE FIRE TEST  
FOR ONE HOUR.  
SITUATION AFTER FIRE EXPOSURE.

SAMPLE AFTERWARDS EXPOSED TO  
THE SALT SPRAY TEST WITH POSITIVE  
RESULTS



**FISSIC® COATING TESTED IN  
THE CLIMATE CHAMBER TO  
LOWEST ENVIRONMENTAL  
TEMPERATURES TO - 72 °C.**

**WEISS**

**-28.8 °C**

**FISSIC® ALSO EXPOSED TO HIGHEST UV RATINGS  
COMBINED WITH DEW IN OUR QUV TEST EQUIPMENT**




**SBI (single burning item) test to determine the reaction to fire performance of FISSIC® COATING < 1 mm thick when exposed to thermal attack. Test according to EN 13823:2010+A1:2014. Test report Y1780-3E-RA Classification to EN 13501-1:2007+A1:2009: B-s1,d0.  
B = classification to reaction to fire (ratings B-D of which B is highest)  
s1 = classification for smoke production (ratings s1, s2, s3) - S1 no smoke  
d0 = classification for flaming droplets (ratings d0, d1, d2) - d0 no droplets**


Applying a FISSIC®-TI layer on a steel pipe for thermal protection with regard to the maximum allowable temperature rise of 180 °C according to the fire testing protocols.



**FISSIC® TI COATING 8 mm THICK  
TESTED TO DETERMINE THER-  
MAL INSULATION PROPERTIES  
DURING A TWO HOUR FIRE  
TEST REACHING 1040 °C.**



FISSIC®-TI coating applied on steel pipes for thermal protection during a 120 minutes fire test according to EN 1366-3:2009. No release of any smoke and thermal insulation below 180 °C.



**TEMPERATURE RISE ON FISSIC TI AFTER 120 MINUTES ON  
4" PIPE 127 °C, ON 6" PIPE 169 °C AND ON 8" STEEL PIPE 151 °C**



Preliminary investigation of the feasibility to determine thermal insulation properties of the FISSIC® coating. Jet fire test carried out May 29, 2015 on two aluminum pipes 65x55 mm with a length of 80 mm. At the left side the aluminum pipe with a 4 mm thick FISSIC® coating and at the right side the non-treated aluminum pipe.



The pipe ends are sealed top/bottom with NOFIRNO® sealant to create tightness between the concrete blocks and the edges of the aluminum pipes. Inside the pipes a thermocouple is fixed against the wall at the spot of the flame exposure to measure temperature rise during fire exposure.






To maximize the heat flux and flame erosion the test was carried out in a small re-circulation chamber. Shortly after 3 minutes the non-treated aluminum pipe started to deform, increasing the flaming inside the chamber and releasing fumes. At 3:40 minutes the aluminum started to melt.



The FISSIC® charred to form its protective layer. After almost 5 minutes the non-treated aluminum pipe lost mechanical stability and started sagging. Flaming intensified as can be seen on this picture.



At 5:03 minutes the melted aluminum dripped of the bottom of the re-circulation chamber.



At 5:37 minutes dripping of the aluminum stopped. Flaming and fuming reduced and stopped in the following seconds.



The thermocouple which was placed inside the non-treated aluminum pipe hanging on top of the melted aluminum. The aluminum cooled down on the concrete due to the fact that the jet flame has a higher position.



The situation after 15 minutes testing. There is not much to see at the surface of the exposed FISSIC®, but the temperature measured inside the aluminum pipe is now close to 600 °C which is more or less the melting temperature of aluminum.



The temperature on the surface of the FISSIC® coating is  $>1000$  °C. At 16 minutes testing the aluminum must have been melted. Obviously the thermocouple must have been covered by the melted aluminum since the temperature rise from 16 to 20 minutes is very limited.



No further changes visible during further testing.



The FISSIC® coating is still in place at the end of the jet test, the NOFIRNO® sealant has formed its protective char also. It looks at the outside of the coated aluminum pipe if nothing has happened.



After 30 minutes the jet fire is extinguished.




Close-up of the FISSIC® treated test specimen and the char of the NOFIRNO® sealant at the end of the jet test.



No after-flaming of the FISSIC® coating and NOFIRNO® sealant.




The performance of the FISSIC® coating is visible after removal of the concrete block at the top of the re-circulation chamber. The melted aluminum at the bottom inside the formed FISSIC® “pipe”. It is also visible that a part of the aluminum pipe is still intact. NOFIRNO has performed as usual under fire load - the terracotta colour still visible beyond the protective char.



**Conclusion:**

An only 4 mm thick layer of FISSIC® coating has protected an aluminum pipe for ca. 15 minutes from melting and collapsing. R&D is ongoing to obtain improved thermal insulation properties to determine the thickness required to protect the aluminum longer and at even higher temperatures as tested now.

Aluminum pipe 5 mm wall thickness coated with 10 mm FISSIC® coating. Due to the thickness of the coating, the coating had to be applied in layers. R&D has meanwhile developed a paste to enable applying the coating in one layer.





## JET TEST ON ALUMINUM PIPES



Second investigation of the feasibility to determine thermal insulation properties of the FISSIC® coating. Jet fire test carried out June 12, 2015 on two aluminum pipes 65x55 mm with a length of 80 mm. At the left side the aluminum pipe with a 10 mm thick FISSIC® coating and at the right side the non-treated aluminum pipe.



The pipe ends are sealed top/bottom with NOFIRNO® sealant to create tightness between the concrete blocks and the edges of the aluminum pipes. Inside the pipes a thermocouple is fixed against the wall at the spot of the flame exposure to measure temperature rise during fire exposure.



To maximize the heat flux and flame erosion the test was carried out in a small re-circulation chamber. The FISSIC® charred to form its protective layer. Shortly after 4 minutes the non-treated aluminum pipe started to deform and fluid aluminum dripped off.



After 5 minutes the non-treated aluminum pipe lost mechanical stability and started sagging. Flaming inside the re-circulation chamber intensified as can be seen on this picture. It looks that the melting/burning aluminum contributes substantially to the fire.



After the aluminum has burned away, leaving reminders on the floor, the intensified flaming disappeared.



Close-up of the FISSIC® coating after almost 10 minutes testing. The coating holds together and does not fall off.



The temperature on the surface of the FISSIC® coating is  $>1000\text{ }^{\circ}\text{C}$ . Temperature on the aluminum inside the pipe at the position of the jet flame is only  $102\text{ }^{\circ}\text{C}$ .



The situation after 15 minutes testing. There is not much to see at the surface of the exposed FISSIC®, The temperature measured inside the aluminum pipe is now  $173\text{ }^{\circ}\text{C}$  against the temperature close to  $600\text{ }^{\circ}\text{C}$  measured after 15 minutes on the aluminum pipe coated with 4 mm FISSIC® in the previous jet test.



The heat inside the re-circulation chamber is increasing. The camera had to be protected with a mineral wool board. Temperature on the aluminum pipe now 260° C.



No further changes.




The situation at the end of the test. Temperature on the aluminum pipe 360 °C, far below the melting point of the aluminum.



Some after-flaming of the FISSIC® coating is visible after the jet flame has been extinguished. This might have been caused by the fact that the FISSIC® coating probably has not fully cured due to the thickness of the layer.



The performance of the FISSIC® coating is visible after removal of the concrete block at the top of the re-circulation chamber. The aluminum pipe is not affected by heat and flames. The FISSIC® layer is broken when the upper concrete block has been removed.



### Conclusion:

An 10 mm thick layer of FISSIC® coating has protected an aluminum pipe during jet fire exposure of 30 minutes from melting and collapsing (max. temperature 360 °C). R&D is ongoing to improve the application methods and to improve time of hardening. Furthermore a higher filling of the compound will be investigated.

After removal of the charred FISSIC® layer it became obvious that the adhesion of the thicker FISSIC® has to be improved. This with a view of future shock testing.





**FISSIC®-TI coating has been formulated to a paste. The coating is light weight and flexible. The thermal insulating properties are higher than those of the standard FISSIC® coating.**



Applying a FISSIC®-TI layer on a steel partition to investigate thermal insulation properties when applied at the exposed side of the fire.



FISSIC®-TI coating applied on a part of a steel partition. R&D is ongoing to develop spraying equipment for the paste.



# FYLLOFYS FISSIC

Testing FYLLOFYS insulation coated with FISSIC® on 8" steel pipes for further development. Temperatures after 1 hour far below max. allowable.






# FYLLOFYS FISSIC

SAFETY  
SEALING  
SYSTEMS

**BEELE**  
WE CARE


Jet Fire on FYLLOFYS coated with FISSIC® to determine thermal insulation and heat sink properties of the combination (TC 5).






Testing FYLLOFYS insulation coated with FISSIC® on a 100x75x7 mm steel angle

Temperature on the steel angel after  
2 hours testing:  
TC 8 112 °C  
TC 9 45 °C





The FISSIC® coating can be applied by airless spraying. Or by brushing.  
The next generations of the compound will be a paste to enable application of thicker layers of the FISSIC® coating and a casting version.



***WE CARE***

**BEELE ENGINEERING:  
A COMPANY DEDICATED TO SAFETY  
FOR OVER 40 YEARS**



**BEELE Engineering bv**  
Beunkdijk 11 - 7122 NZ AALTEN - THE NETHERLANDS  
Tel. +31 543 461629 - Fax +31 543 461786 - E-mail: [info@beele.com](mailto:info@beele.com)  
Websites: <http://www.beele.com>, [sealingvalley.com](http://sealingvalley.com) and [fissiccoating.com](http://fissiccoating.com)